


BUILDING SAFETY CERTIFICATE


The School building of Gyan Vidya Peeth Secondary level School (Jangal) Tehsil Jaisinghpur Distt. Kangra (HP) was inspected by the Assistant Engineer Balakrupi along with concerned Junior Engineer of Alampur section on dated 05-11-2024 . It has been observed that no earthquake resistant provision have been adopted for this building and no structural drawing approved by the competent Govt. Certified Engineer have been produced at the time of inspection. Moreover no assistance was taken from PWD for constructing the building. This structure is non engineered structure. Hence the structural safety of this building cannot be ensured specifically from earthquake resistance point of view. This department will not be responsible for any type of loss of life and property etc. if this structure fails under any circumstances.

However as per visual inspection the building has been found safe at present only. No officer/official of this office will attend plead in any Hon'ble court of Law in case any dispute.

Note: - This certificate is valid for one year academic Session 2025-26 or till any addition or substantial change in loading of building structure is made.


Executive Engineer
Jaisinghpur Division
HPPWD Jaisinghpur


Assistant Engineer,
Balakrupi Sub -Division,
HPPWD Balakrupi


Principal
Gyan Vidya Peeth, Jangal
(Alampur) Distt. Kangra (H.P.)